

US Consumer Product Safety Commission Log of Meeting

Subject: NFPA Technical Committee Meeting on Private Water Supply Piping Systems

Date: August 3, 2022, 10 am to 2 pm ET

Location: Teleconference

Prepared By: Chen-hsiang Su (csu@cpsc.gov, 301-987-2529), August 16, 2022

CPSC Attendees: Chen-hsiang Su

Non-CPSC Attendees: Contact NFPA a complete list of attendees.

Summary of Meeting:

Contact NFPA for more details of this meeting.

This was a technical committee first draft meeting (A2024) for NFPA 24: *Standard for the Installation of Private Fire Service Mains and Their Appurtenances*. The primary purpose of this meeting was to review the public inputs and develop proposed revisions recommended by the committee.

The meeting started with introducing and reviewing of the code of conduct and approval of the previous meeting minutes. The committee then reviewed the public inputs for NFPA 24. Among other public inputs, the committee discussed the proposal of using the hydrostatic test pressure of a fire service main system as the working pressure for the purpose of calculating and designing thrust blocks. Staff commented that the hydrostatic test pressure is specifically for hydrostatic testing while working pressure has its own definition. The committee agreed to form a task group to look further into the subject.

The meeting was adjourned around 4 pm and the schedule for the next meeting will be determined later.